

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	NI013782-R1
DATE:	07/12/2017
CERTIFICATION PROGRAM:	Fire
COMPANY:	Seves Glass
CODE:	2322-1
REVISION DATE:	11/01/2021
EXPIRATION DATE:	07/31/2024

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Seves Glass Block, Inc.</p> <p>10576 Broadview Road</p> <p>Broadview Heights, OH 44147</p>	<p style="text-align: center;">Series "Vetropieno"</p> <p style="text-align: center;">Fire-Rated Solid Glass Block</p> <p style="text-align: center;">Manufacturer Specific Glass Blocks for Installation in 90 Minute Locations</p> <p style="text-align: center; margin-top: 20px;">Max Opening: 100ft² or W-120" or H-121"</p> <p style="text-align: center; margin-top: 20px;">Glass Block Size: W-9.45" x H-2.09" Minimum Thickness: 4.61"</p>

SPECIFICATION	PRODUCT RATING
NFPA 257 (2000)	90 Minutes With Hose Stream

TEST REPORT
Architectural Testing Inc. Test Report No: C9707.01-121-24

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Fax: (804) 684-5122