

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013704.04-R2
DATE: 03/13/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Seves Glass
CODE: 2322-1
REVISION DATE: 10/04/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Seves Glass Block, Inc. 10576 Broadview Road Broadview Heights, OH 44147	“Residential Hurricane Resistant Windows w/Thickset 90 Series Glass Block & ProVantage Silicone System” Configuration: O Glazing: 3.88" Thickset® 90 Glass Block Panels Frame: W-1807mm (71.13") H-1807mm (71.13") Block Size: W-203mm(8") H-203mm(8")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±3256 Pa (68 psf) Large Missile Impact Rated

Product Tested By: Architectural Testing, Inc.
Report No: 01-44639.03
Expiration Date: March 31, 2024

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023