

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015719-R1
DATE: 01/16/2023
CERTIFICATION PROGRAM: Fire
COMPANY: Seves Glass
CODE: 2322-1
REVISION DATE: 01/08/2025
EXPIRATION DATE: 05/31/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Seves Glass Block S.R.O. Bilinská 782/42 Duchcov, 419 01, Czech Republic	Series "1919_13 F120" Fire-Rated Seves Glass Block Unit (w/ (2) 0.25" x 1.5" Strong-Tie SDS HD Connector Screw Double-Barrier Coating/16" O.C. Both Sides/ Lehigh Heidelberg Type S Masonry Cement w/Crystalline Silica/4" Truss type 9-Gauge wire reinforcement & 3M Fire Barrier Water Tight Sealant 1000 NS) Manufacturer Specific Glass Blocks for Installation in 120 Minute Locations Max Opening: 137ft ² or W-124.63" & H-163.69" Minimum Glass Block Thickness: 5.13"

SPECIFICATION	PRODUCT RATING
ASTM E119-20 UL 263-19 CAN/ULC-S101-14	120 Minutes With Hose Stream

TEST REPORT
ICC NTA, LLC Test Report No: SGB1042921-110

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124
nami@namiinc.com

NOPC-03/30/2023