



A
B
C
D
E
F
G
H
J
 N:\ENGINEERING\CONSTRUCTION DETAILS\FIRE RATED\FR-121 JAMB - 60 MIN FIRE RATED GLASS BLOCK IN METAL STUD OR CONC WALL\FR-121.DWG | PLOTTED 10.12.2022 10:56AM BY IRIZARRY MICHAEL

- WALL CONFORMING TO UL® DESIGN NO. U465
- INSULATION
- SEVES STAINLESS STEEL PANEL ANCHOR W/ TWO S.S. FASTENERS
- SEVES EXPANSION STRIP
- SEVES GLASS BLOCK, THICKSET® 60
- FIRE RETARDANT TYPE SEALANT (TYP)
- METAL STUD FRAMING

JAMB - 60 MIN FIRE RATED GLASS BLOCK IN METAL STUD WALL

- FIRE RETARDANT TYPE SEALANT (TYP)
- SEVES GLASS BLOCK, THICKSET® 60
- SEVES STAINLESS STEEL HORIZONTAL PANEL ANCHOR & WIRE REINFORCING INSTALLED AT TOP OF FIRST COURSE, BEFORE THE LAST COURSE AND 16" O.C. IN BETWEEN. MECHANICALLY FASTENED TO STRUCTURAL JAMB, FASTENERS BY OTHERS
- SEVES EXPANSION STRIP
- CMU/CONCRETE WALL

JAMB - 60 MIN FIRE RATED GLASS BLOCK IN CMU/CONCRETE WALL

CONFIDENTIAL - PROPRIETARY THESE DRAWINGS WERE CREATED BY AND REMAIN THE PROPERTY OF SEVES GLASS BLOCK S.R.O. UNAUTHORIZED DISCLOSURE, DISTRIBUTION OR COPYING OF THESE DRAWINGS IS STRICTLY PROHIBITED. THE FOLLOWING DETAILS ILLUSTRATE DESIGN INTENT; VARIATIONS MAYBE ACCEPTABLE. PLEASE CONTACT SEVES GLASS BLOCK TECHNICAL DEPARTMENT FOR FURTHER CONSULTATION.



PROJECT FIRE RATED CONSTRUCTION DETAIL		
TITLE JAMB - 60 MIN FIRE RATED GLASS BLOCK IN METAL STUD OR CONCRETE WALL		
SCALE 3"=1'-0"	DWG. NO. FR-121	REV 0
BY MAI	DATE 010/12/2022	SHEET 1